

Statement of Network Safety Performance Objectives (2018)





#### Context & Purpose

The Horizon Power Network Safety Objectives (2018) (**Objective Statement**) has been prepared for each of the network safety performance incident types detailed in Regulation 30 and in accordance with the requirements set out in Regulation 31 of the Electricity (Network Safety) Regulations 2015.

This Objective Statement sets out the objectives in relation to the maximum number of incidents expected to occur, and covers financial years 2018/19 to 2021/2022.

## **Objective Establishment**

Horizon Power has applied a causal forecasting – input-output methodology to the majority of the network safety performance incident types, with the exception of property damage (Regulations r. 30(1) (b) and r.30 (1) (c)). This method is well suited to Horizon Power as:

- 1. It can assess all historical Network Safety Performance Incidents
- 2. It allows the level of confidence in historical data quality to be factored into forecasts via a smoothing parameter which can assign greater weight to more recent network safety performance data
- 3. It is a best practice approach to forecasting, utilising an underlying mathematical model known as a "Multiplicative Damped Trend"

Where possible, Horizon Power incorporates industry statistics as a benchmark against which reasonable Objectives can be set. Network performance against these Objectives is then used in the Asset Management Planning process, which provides a risk-based framework for identifying and planning the capital and operational works.

## **Objective Statement**

This Objective Statement provides the objectives that Horizon Power will strive to achieve in the maintenance and operation of its network.

# Network Safety Performance Objectives (2018)



			Incidents			
Network Objectives		2018/19	2019/20	2020/21	2021/22	
30(1)(a)	Total Electric Shock	5	5	5	5	
	Person – No Injury	5	5	5	5	
	Person – Injury	0	0	0	0	
	Person – Death	0	0	0	0	
	Livestock – Death	0	0	0	0	
30(1)(b)	Total Property Damage (Not Fire)	0	0	0	0	
30(1)(c)	Total Property Damage (Fire)	0	0	0	0	

		Incidents			
Distribution Network Objectives		2018/19	2019/20	2020/21	2021/22
30(1)(d)	Total Pole Fire	9	9	9	9
30(1)(e)	Total Conductor Clashing <sup>2</sup>	6	6	6	6
30(1)(f)	Total Unassisted Pole Failure	9	9	9	9
	Wood	4	4	4	4
	Steel <sup>1</sup>	5	5	5	5
	Other	0	0	0	0
30(1)(g)	Total Unassisted Conductor Failure	10	10	10	10
30(1)(h)	Total Unassisted Stay Failure <sup>3</sup>	3	3	3	3
30(1)(i)	Total Unassisted Cable Failure	14	14	14	14
31(3)	Total Unassisted Pole Failure Rate	1.6	1.6	1.6	1.6
	Wood x 10,000 p.a.	2.3	2.3	2.3	2.3
	Steel <sup>1</sup> x 10,000 p.a.	1.3	1.3	1.3	1.3

# Network Safety Performance Objectives (2018)



		Incidents				
Transmission Network Objectives		2018/19	2019/20	2020/21	2021/22	
30(1)(d)	Total Pole Fire	0	0	0	0	
30(1)(e)	Total Conductor Clashing <sup>2</sup>	0	0	0	0	
30(1)(f)	Total Unassisted Pole Failure	0	0	0	0	
	Wood	0	0	0	0	
	Steel	0	0	0	0	
	Other	0	0	0	0	
30(1)(g)	Total Unassisted Conductor Failure	0	0	0	0	
30(1)(h)	Total Unassisted Stay Failure <sup>3</sup>	0	0	0	0	
30(1)(i)	Total Unassisted Cable Failure	0	0	0	0	
31(3)	Total Unassisted Pole Failure Rate	0	0	0	0	
	Wood x 10,000 p.a.	0	0	0	0	
	Steel x 10,000 p.a.	0	0	0	0	

#### Notes

- 1. Unassisted steel pole failures and failure rates include all steel poles
- 2. Unassisted conductor clashing objectives are based on reported incidents this does not capture all clashing incidents occurring on the network
- 3. Unassisted stay failure objectives are based on reported incidents this does not capture all stay failure incidents occurring on the network

# Network Safety Performance Objectives (2018)



Network Safety Performance Incident Definitions

#### A discharge of electricity from the network that causes the electric shock, injury or death of a person or the death of Electric Shock 30(1)(a) livestock (excluding pets). Property Damage (Not Fire) An incident caused by the network, other than a fire, that causes damage to property other than to the network. 30(1)(b) Includes supply, impact and arcing damage. Value of damage must exceed or be likely to exceed \$5,000. Property Damage (Fire) A fire caused by the network that causes damage to property other than to the network. Includes smoke and heat 30(1)(c) damage. Value of damage must exceed or be likely to exceed \$5,000. Pole Fire A fire, on a pole that is a part of the network, that originated on the pole. Includes burnt cross arms. 30(1)(d) Conductor Clashing The contacting of 2 or more conductors of the network, of different phases, caused by temperature variations or wind. 30(1)(e) Includes clashing due to pole lean and phase to earth clashing. Excludes assisted failures [see 28(c)]. Unassisted Pole Failure An unassisted failure of a pole that is a part of the network. Includes suspended failures and foundation failure [i.e. 30(1)(f) excessive pole lean]. 30(1)(q)Unassisted Conductor Failure An unassisted failure of an overhead conductor that is a part of the network. Includes: service wires, joints. Excludes: termination points, taps, conductor accessory & line hardware failures [e.g. ties, clamps]. 30(1)(h) Unassisted Stay Failure An unassisted failure of a stay wire that is a part of the network. Includes slack stays and failure of anchors and attachment points that compromise line design integrity in a way that impacts public safety. 30(1)(i) Unassisted Cable Failure An unassisted failure of an underground cable that is a part of the network. Includes: joints, termination kits. Excludes: termination points, lugs & cable accessories [e.g. clamps]. Unassisted Pole Failure Rate The failure rate per 10,000 poles per annum based on the 30(1)(f) and pole volumes. 31(3) 28(c) **Unassisted Failure** Unassisted failure, of a pole, overhead conductor, stay wire or underground cable, means the pole breaking or collapsing, the conductor or wire breaking or the cable failing, otherwise than because of — (a) a force exceeding the failure limit or design wind load specified in the applicable standard; or (b) a lightning strike, earthquake, fire or flood; or (c) malicious damage; or (d) excavation other than by a person for whom the network operator is responsible; or (e) any other similar occurrence beyond the control of the network operator. A failure is unassisted if it is due incorrect network design | construction or vegetation growth into the vegetation clearance zone.